

**QUALITY CONTROL PROGRAM
CERTIFICATE OF
REGISTRATION AND
CONTRACTOR'S LICENCE**

Techmation Electric & Controls LTD.

**117 Kingsview Road South East
Airdrie, Alberta
T4A 0A8**

This certificate authorizes the holder listed above to perform the work as shown in the scope below in accordance with *The Boiler & Pressure Vessel Act, 1999*

SCOPE

ASME B31.1 Power Piping - Construct, Repair and Alteration (Field Only)

ASME B31.3 Process Piping - Construct, Repair and Alteration (Field Only)

ASME B31.5 Refrigeration Piping - Construct, Repair and Alteration (Field Only)

ASME B31.9 Building Services Piping - Construct, Repair and Alteration (Field Only)

Manual: With the Latest Revision # 1 Latest Revision Date: 12/Jan/2015

Within Saskatchewan controlled from the above address.



AUTHORIZED: February 28, 2015

EXPIRES: February 28, 2018

QCP CERTIFICATE/LICENCE NO.: 0531 - 01

Chief Inspector

February 17, 2015

Techmation Electric & Controls LTD.
117 Kingsview Road South East
Airdrie, Alberta T4A 0A8

ATTENTION: Blaine Benjamin

RE: QUALITY CONTROL PROGRAM REGISTRATION
REF#: 1260 (QCP - 0531)

Dear Sir/Madame:

Thank you for submitting your Quality Control Program for review, audit and registration. As a result of a successful review and audit, your quality control program will be approved for use within the Province of Saskatchewan once the attached Out-of-Province Declaration has been signed and returned to our office. Please find included your new Certificate of Registration, and ensure a copy of it is inserted in all controlled manuals along with a copy of the signed declaration.

Please ensure that your Contractor's Licence is up to date. As a reminder, within the Province of Saskatchewan no person shall engage in the business of construction, repair or alteration of pressure equipment without a valid Contractor's Licence.

If you should require any further assistance, please do not hesitate to contact the undersigned below. Please refer to the above reference number on all correspondence.

Yours truly,



Mohammad Ghahremani, P.Eng
Boiler and Pressure Vessel Safety Inspector
mohammad.ghahremani@tsask.ca
(306)-798-0003

January 15, 2015

Company: Techmation Electric & Controls Ltd
117 Kingsview Road SE
Airdrie, AB T4A 0A8
Attention: Blaine Benjamin


REF#: 1260 (QCP- 0531)

Manual with the Latest Revision 1 dated 12/Jan/2015
Additional Out-of-Province Quality Control Program Criteria

1. References in your manual to another Jurisdictional Authority will be considered to apply to the Saskatchewan Jurisdiction Authority and our inspection personnel.
2. References to "routine repairs" will only be accepted as those specified in the NBIC. Reference to an owner performing acceptance examination, inspection, non-conformance resolution and certification functions shall only be performed under an approved Quality Management System.
3. The Authorized Inspector must be notified prior to the start of any work, as well of any material substitution made to a registered design.
4. For pressure piping systems exceeding 0.5 cubic meters of internal volume, no work shall commence until design drawing application has been approved by our department unless the following points have been addressed:
 - The design package shall have been submitted for registration prior to fabrication.
 - The authorized inspector shall have been notified for permission to begin construction prior to fabrication.
 - The design cannot be commissioned into operating service until design registration is completed.
 - Any deficiencies identified through the registration process shall be corrected to the satisfaction of the authorized inspector.
 - The owner shall agree to all these conditions in writing.
5. Welders working within Saskatchewan must hold valid welding licences issued by the Saskatchewan Jurisdiction Authority for all processes being used and all welding procedures must be registered as well.
6. Only CGSB certified personnel are acceptable in Saskatchewan.
7. All pneumatic testing (regardless of volume) requires prior approval of the Jurisdiction Inspector.
8. All construction, repair and alterations on boilers, pressure vessels and pressure piping must be performed in accordance with the requirements of CSA-B51
9. A copy of the Saskatchewan Certificate of Authorization and this letter (signed and dated) is to be inserted into each manual being used within Saskatchewan.
10. **Prior to the start of any fabrication**, written notification (in the form of an Examination and Inspection Sheet or a Travel Sheet) of work to be performed in the Province of Saskatchewan will have to be forwarded(mailed or faxed) to the Authorized Inspector for review and designation of hold points
11. **TITLE PAGE**
 - The reference codes must be listed. CSA-B51, NBIC
12. **SCOPE / CONTRACT REVIEW**
 - **Must indicate that any subcontracted work must also be preformed under an approved QCP accepted by your company**

Refer to <http://www.tsask.ca/Boiler-and-Pressure-Vessel-Safety-forms> for updated provincial forms for inclusion or replacement in your exhibits. Installation, Repair and Alteration Permits (LIB-0001) must be submitted for all work done in Saskatchewan.

I have read the above conditions and acknowledge that any work performed within the Province of Saskatchewan will comply with the above listed conditions in addition to the submitted manual. A copy of this letter will be kept in all controlled manuals.



Signature

Feb 13/15.

Date